



Dolan Chemical Laboratory  
4001 Bixby Road  
Groveport, OH 43125  
T: 614-836-4221, Audinet 210-4221  
F: 614-836-4168, Audinet 210-4168  
<http://aepenv/labs>

## Water Analysis

**Location: Mountaineer Plant**

**Report Date: 10/30/2012**

### CPS Effluent

**Sample Number: 124621-001**

**Date Collected: 10/24/2012 08:00**

**Date Received: 10/24/2012**

Parameter	Result	Units	RL	MDL	Analysis By	Analysis Date/Time	Method
Selenium, Se	432	ug/L	0.5	0.1	DPC	10/30/2012 10:21	EPA 200.8
Bromide, Br	23.9	mg/L	5	1	CRJ	10/26/2012	EPA 300.1
Chloride, Cl	2990	mg/L	20	5	CRJ	10/26/2012	EPA 300.1
Fluoride, F	54.4	mg/L	1	0.2	CRJ	10/26/2012	EPA 300.1
Sulfate, SO4	5530	mg/L	100	30	CRJ	10/26/2012	EPA 300.1

A handwritten signature in black ink that reads 'Brian S. Snyder'.

**Brian Snyder, Chemist II**

Email [bssnyder@aep.com](mailto:bssnyder@aep.com)

Tel. 614-836-4224

Fax 614-836-4168

Audinet 210-4224

**THIS TEST REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT WRITTEN APPROVAL OF THE LABORATORY. ALL TEST RESULTS MEET ALL OF THE REQUIREMENTS OF THE ACCREDITING AUTHORITY, UNLESS OTHERWISE NOTED.**